

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Pine Grove Lift Station Pump

DATE OF MEETING: July 10, 2018

BUDGET IMPACT: \$12,671.60

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Pine Grove Lift Station Pump

The Pine Grove lift station is a duplex station on our trunk line that serves the Bemiss, North Lowndes area. This station is currently running on one pump. The pump out of service is a 30 horsepower Flygt pump. We have a quote from Xylem Inc. to repair this pump for \$12,671.60. Additionally, we have a quote for a new replacement pump from Xylem Inc. for \$25,438.00. Staff recommends the pump be repaired for \$12,671.60.


- OPTIONS: 1. Approve Pump Repair
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump repair for \$12,671.60

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____