

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Data Center Battery Replacement

DATE OF MEETING: February 14, 2017

BUDGET IMPACT \$20,600.00

FUNDING SOURCE

- Annual
- Capital
- N/A

- Regular Meeting
- Work Session
- Recommendation
- Policy/Discussion
- Report
- Other

COUNTY ACTION REQUESTED ON: APC Battery Replacement

HISTORY, FACTS AND ISSUES:

The data center's uninterruptible power system (UPS) batteries in the Judicial/Administrative Complex have reached end of life and are over seven years old and need to be replaced. The device supports all the servers, networking, fire alarm and security systems located in the building by providing clean, stable electrical power in the event of a service interruption. The request will replace 42 batteries. The battery replacement will also allow the vendor to change out a part of the device that is recalled. They are requiring batteries to be in-service before the change out will be scheduled.


- OPTIONS:
- 1. Approve
 - 2. Board's Pleasure

RECOMMENDED ACTION: Board's Pleasure

DEPARTMENT: I.T.S

Department Head: Aaron Kostyu

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:



County Manager

Action Taken By Board: _____