

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Hwy 84 Lift Station Pump

DATE OF MEETING: May 9, 2017

BUDGET IMPACT: \$16,687.20

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Hwy 84 Lift Station Pump Repair

HISTORY, FACTS, AND ISSUES: Hwy 84 lift station is a duplex station that is currently running on one pump. The pump that is out of service is a 70 horsepower Flygt pump. The county has a quote from Xylem Inc. to repair this pump for \$16,687.20. Additionally, the county has a quote for a new 70 horsepower pump from Xylem for \$48,244.00. Staff recommends the pump be repaired at a cost of \$16,687.20.

- OPTIONS: 1. Approve Pump Repair
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump repair from Xylem Inc. for \$16,687.20

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____