

LOWNDES COUNTYBOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Bevel Creek Lift Station Pump

DATE OF MEETING: May 8, 2018

BUDGET IMPACT: \$41,109.10

FUNDING SOURCE

- Annual SPLOST VII
 Capital
 N/A

- Regular Meeting (X)
Work Session (X)
Recommendation ()
Policy/Discussion ()
Report ()
Other ()

COUNTY ACTION REQUESTED ON: Bevel Creek Lift Station Pump

HISTORY, FACTS, AND ISSUES: The Bevel Creek lift station is a triplex lift station on our main trunk line that delivers over 60% of our wastewater flow to the LAS. This station is currently running on two pumps. We have a quote from Xylem Inc. to repair this pump for \$37,380.35. Additionally we have a quote for a new replacement pump, from Xylem Inc. for \$41,109.10. Staff recommends a new pump be purchased for \$41,109.10


- OPTIONS: 1. Approve Pump Purchase
2. Board's Pleasure

RECOMMENDED ACTION: Approve pump purchase for \$41,109.10

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:


County Manager

Action Taken By Board: _____