

LOWNDES COUNTYBOARD OF COMMISSIONERS  
COMMISSION AGENDA ITEM

SUBJECT: Bevel Creek Lift Station Pump

DATE OF MEETING: May 8, 2018

BUDGET IMPACT: \$41,109.10

FUNDING SOURCE

- Annual                       SPLOST VII  
 Capital  
 N/A

- Regular Meeting (X)  
Work Session (X)  
Recommendation ( )  
Policy/Discussion ( )  
Report ( )  
Other ( )

COUNTY ACTION REQUESTED ON: Bevel Creek Lift Station Pump

HISTORY, FACTS, AND ISSUES: The Bevel Creek lift station is a triplex lift station on our main trunk line that delivers over 60% of our wastewater flow to the LAS. This station is currently running on two pumps. We have a quote from Xylem Inc. to repair this pump for \$37,380.35. Additionally we have a quote for a new replacement pump, from Xylem Inc. for \$41,109.10. Staff recommends a new pump be purchased for \$41,109.10

- OPTIONS: 1. Approve Pump Purchase  
2. Board's Pleasure


RECOMMENDED ACTION: Approve pump purchase for \$41,109.10

DEPARTMENT: Utilities

Department Head: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATION:

\_\_\_\_\_  
\_\_\_\_\_

  
County Manager

Action Taken By Board: \_\_\_\_\_