

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: KOA Lift Station Emergency Repair

Work Session/Regular Session

DATE OF MEETING: June 25, 2019

BUDGET IMPACT: \$49,400.00

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: KOA Lift Station Emergency Repair

HISTORY, FACTS AND ISSUES: The 8" line between the manhole and lift station wet well has collapsed. This has created a sink hole effect with sand filling the wet well. A new manhole will be set and 40' of 8" pipe will be jack and bored to connect the new manhole to the wet well. RPI, Inc. has provided a quote for \$49,400.00 to provide the materials and perform the work.

- OPTIONS: 1. Approve
2. Board's pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: