

LOWNDES COUNTY BOARD OF COMMISSIONERS
COMMISSION AGENDA ITEM

SUBJECT: Whitewater Road Lift Station Pump

Work Session/Regular Session

DATE OF MEETING: February 9, 2021

BUDGET IMPACT: \$39,158.70

FUNDING SOURCE:

- Annual
- Capital
- N/A
- SPLOST
- TSPLOST

COUNTY ACTION REQUESTED ON: Whitewater Road Lift Station Pump

HISTORY, FACTS AND ISSUES: Pump number two at the Whitewater Road lift station began reading high amps. The pump was pulled and sent to Xylem's shop for analysis & repairs. The price to repair the pump is \$43,926.30 which exceeds the cost of a new pump. The cost for a new pump is \$39,158.70. Staff recommends purchasing a new pump from Xylem for \$39,158.70.

OPTIONS: Approve
Board's Pleasure

RECOMMENDED ACTION: Approve

DEPARTMENT: Utilities

DEPARTMENT HEAD: Steve Stalvey

ADMINISTRATIVE COMMENTS AND RECOMMENDATIONS: