

WATER QUALITY IN LOWNDES COUNTY

North Lowndes County Water System WSID # 1850016

South Lowndes County Water System WSID # 1850019

Kinderlou Forest Water System WSID # 1850319

Alapaha Plantation Water System # 1850274

Creekside West Water System # 1850322

Spring Creek Water System # 1850297

We're pleased to present you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our resources. We are committed to ensuring the quality of your water. Our water is pumped from the Upper Floridian Aquifer.

We are also pleased to report our drinking water meets federal and state requirements. This report shows our water quality and what it means.

Special Population Advisory

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Center For Disease Control guidelines on how to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline 800-426-4791.

Public Participation Opportunities

We want our valued customers to be informed about their water utility. If you want to learn more, please attend any regularly scheduled Commissioners meetings. They are held at 327 North Ashley Street on the second and fourth Tuesday of the month at 5:30 pm.

Contaminants in Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline 800-426-4791.

Drinking Water Sources

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water before we treat it include:

- *Microbial contaminants*, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- *Pesticides & herbicides*, which may come from a variety of sources such as agriculture and residential use.
- *Radioactive contaminants*, which are naturally occurring.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also can come from gas stations, urban storm water runoff, and septic systems.

Water Quality Monitoring

To ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. We treat our water according to EPA's regulations. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Water Quality Data

The table in this report lists all the drinking water contaminants we detected during the 2011 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 through December 31, 2011. The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, is more than one year old.

Lowndes County Utilities works around the clock to provide top quality water to every tap. We ask that all our customers help us protect and conserve our water sources; they are the heart of our community, our way of life and our children's future.

Terms & Abbreviations

- **AL: Action Level** - the concentration of a contaminant which, when exceeded, triggers treatment or other requirements that a water system must follow.
- **MCLG: Maximum Contaminant Level Goal** - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MCL: Maximum Contaminant Level** - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **mg/L: milligrams per liter**--- (corresponds to the equivalent of ppm)
- **N/A: not applicable**
- **ND: Not detectable at testing limit**
- **ppm: parts per million or milligrams per liter** -- (corresponds to one minute in two years)
- **ppb: parts per billion or micrograms per liter** --(corresponds to one minute in 2,000 years)
- **pCi/L: Picocuries per liter** (a measure of radiation)
- **µg/L: Micrograms per liter** - (corresponds to the equivalent of **ppb**)
- **Maximum Residual Disinfectant Level (MRDL)** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbiological contaminants.
- **Maximum Residual Disinfectant Level Goal (MRDLG)** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Lowndes County water systems are responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

North Lowndes Water System # 1850016

Contaminant	MCL in mg/L	MCLG	Our Water	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Inorganic Contaminants							
Copper (ppb)	1300 (AL)	1300	1000	0 samples above AL	2009	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	15 (AL)	0	15	0 samples above AL	2009	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	2	2	0.9	0.4 – 1.2	Monthly	NO	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Volatile Organic Contaminants (REGULATED)							
Total Trihalomethanes (µg/L)	80	NA	57.13	35.1 – 73.1	2010	NO	Disinfection byproducts
Haloacetic Acids (µg/L)	60	NA	47.38	15.5 – 66	s2010	NO	Disinfection byproducts
Free Chlorine Residuals							
Free Chlorine (mg/L)	4.0 MRDL	4.0 MRDLG	1.0	.2 – 2.9	Daily	NO	Chemical added for disinfection
Microbiological Contaminants							
Total Coliform Bacteria (TC)	<5% positive	Zero samples positive	0%	0.0	Monthly	NO	Coliform bacteria are naturally present in the environment

This is a combined water system purchasing water from the City of Valdosta and from the Counties existing well and elevated tank.

This water quality report was prepared by Lowndes County Utilities.

South Lowndes Water System # 1850019

Substance	MCL	MCLG	Our Water	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Inorganic Contaminants							
Copper (ppb)	1300 (AL)	1300	390	0 sample above AL	2007	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Fluoride (ppm)	2	2	.9	0.6 – 1.3	Monthly	NO	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Lead (ppb)	15 (AL)	0	2.5	1 sample above AL	2007	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Free Chlorine Residuals							
Free Chlorine (mg/L)	4.0 MRDL	4.0 MRDLG	0.9	0.2 – 1.6	Daily	NO	Chemical added for disinfection
Volatile Organic Contaminants							
Total Trihalomethanes (µg/L)	80	N/A	67.8	67.8	2011	NO	Disinfection byproduct
Haloacetic acids (µg/L)	60	N/A	10.3	10.3	2011	NO	Disinfection byproduct
Microbiological Contaminants							
Total Coliform Bacteria (TC)	<5% positive	Zero samples positive	0%	0.0	Monthly	NO	Coliform bacteria are naturally present in the environment

This water quality report was prepared by Lowndes County Utilities.

Kinderlou Forest Water System # 1850319

Contaminant	MCL in mg/L	MCLG	Our Water	Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Inorganic Contaminants							
Copper (ppb)	1300 (AL)	1300	72	25 - 470	2010	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	15 (AL)	0	2.5	0 - 18	2010	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	2	2	.8	0.2 – 1.7	Monthly	NO	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Free Chlorine Residuals							
Free Chlorine (mg/L)	4.0 MRDL	4.0 MRDLG	1.2	0.2 – 2.1	Daily	NO	Chemical added for disinfection
Volatile Organic Contaminants							
Total Trihalomethanes (µg/L)	80	N/A	33.5	33.5	2011	NO	Disinfection byproduct
Haloacetic acids (µg/L)	60	N/A	20.6	20.6	2011	NO	Disinfection byproduct
Microbiological Contaminants							
Total Coliform Bacteria (TC)	<5% positive	Zero samples positive	0%	0.0	Monthly	NO	Coliform bacteria are naturally present in the environment

This water quality report was prepared by Lowndes County Utilities.

Creekside West Water System # 1850322

Contaminant	MCL in mg/L	MCLG	Our Water	Result/Range of Detection	Sample Date	Violation (Y or N)	Typical Source of Contamination
Inorganic Contaminants							
Copper (ppb)	1300 (AL)	1300	44	0 – 83	2010	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	15 (AL)	0	3.8	0 – 3.8	2010	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	4	4	.9	.5 – 1.6	Monthly	NO	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Volatile Organic Contaminates (REGULATED)							
Total Trihalomethane (ug/L)	80	NA	17.8	17.8	2011	NO	Disinfection byproducts
Haloacetic Acids (ug/L)	60	NA	6.4	6.4	2011	NO	Disinfection byproducts
Free Chlorine Residuals							
Free Chlorine (ppm)	4	4	1.4	.3 – 4.4	Daily	NO	Chemical added for Disinfection
Microbiological Contaminants							
Total Coliform Bacteria (TC)	<5% positive	Zero samples positive	0%	0.0	Monthly	NO	Coliform bacteria are naturally present in the environment

This water quality report was prepared by Lowndes County Utilities.

Alapaha Plantation Water System # 1850274

Contaminant	MCL in mg/L	MCLG	Our Water	Result/Range of Detection	Sample Date	Violat ion (Y or N)	Typical Source of Contamination
Inorganic Contaminants							
Copper (ppb)	1300 (AL)	1300	325	0 - 520	2007	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	15 (AL)	0	8.7	2.5 - 11	2007	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	4	4	.9	0 – 2.2	Monthly	NO	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Volatile Organic Contaminants (REGULATED)							
Total Trihalomethanes (µg/L)	80	NA	153	28 – 226	2011	YES	Disinfection byproducts
Haloacetic Acids (µg/L)	60	NA	105	19 - 150	2011	YES	Disinfection byproducts
Free Chlorine Residuals							
Free Chlorine (ppm)	4	4	1.6	.2 -4.4	Daily	NO	Chemical added for Disinfection
Microbiological Contaminants							
Total Coliform Bacteria (TC)	<5% positive	Zero samples positive	0%	0.0	Monthly	NO	Coliform bacteria are naturally present in the environment

This water quality report was prepared by Lowndes County Utilities.

SPRING CREEK WATER SYSTEM # 1850297

Contaminant	MCL in mg/L	MCLG	Our Water	Result/Range of Detection	Sample Date	Violat ion (Y or N)	Typical Source of Contamination
Inorganic Contaminants							
Copper (ppb)	1300 (AL)	1300	225	0 – 450	2008	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	15 (AL)	0	0	0	2008	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Fluoride (ppm)	4	4	.9	0.4 – 1.3	Monthly	NO	Erosion of natural deposits; water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Volatile Organic Contaminates (REGULATED)							
Total Trihalomethane (ug/L)	80	NA	62.4	41.9.0 – 82.9	2009	NO	Disinfection byproducts
Haloacetic Acids	60	NA	88.15	74.1 – 102.2	2009	YES	Disinfection byproducts
Free Chlorine Residuals							
Free Chlorine (ppm)	4	4	.70	0.20 – 1.10	Daily	NO	Chemical added for Disinfection
Microbiological Contaminants							
Total Coliform Bacteria (TC)	<5% positive	Zero samples positive	0%	0.0	Monthly	NO	Coliform bacteria are naturally present in the environment

This is a combined water system purchasing water from the City of Valdosta and from the Counties existing well and elevated tank.

This water quality report was prepared by Lowndes County Utilities.